

Acceleration of energy model input

Summer internship defense 2023



Iman BARKAN , Wednesday, 23 August 2023

Table of contents

- 1- INTRODUCTION AND OBJECTIVES
- 2- TEST CASE PRESENTATION
- 3- BUILDING DATA COLLECTION
- 4- MULTIZONE BUILDING MODEL
- 5- SIMULATION RESULTS AND ANALYSIS
- 6- CONCLUSION AND PERSPECTIVES
- 7- MY EXPERIENCE

1- INTRODUCTION AND OBJECTIVES

Introduction



National Energy Conservation Context:

- Goal: Reduce energy consumption by 10% by 2024.
- Building industry in France:
 - ➡ Major energy consumer.
 - ➡ Accounts for 25% of national greenhouse gas emissions.


Cemosis & Iloomi Collaboration:

Main Goals:

- ✓ Iloomi's comprehensive homeowner questionnaire development.
- ✓ Automate creation of energy models at building scale using building geometry.




Workflow Diagram of the Energy Model Input Process



2- TEST CASE PRESENTATION


Introducing iLoomi's Single House Test Case

54 Av. de Paris, 59155 Faches-Thumesnil




Excerpt from the energy audit provided by iLoomi


3- BUILDING DATA COLLECTION




3- BUILDING DATA COLLECTION




Overview of the automated data collection process




Descriptive plans of the studied piece




ILoomi's Test Case House: Front View and Side View of the House




Wall's orientation (Obtained with our Building Module)



4- MULTIZONE BUILDING MODEL



4- MULTIZONE BUILDING MODEL



Thermal Modelisation

The heat transfer balance equation:

$$\begin{cases} m_i C p_i \frac{\partial T_i}{\partial t} = DFS + \sum_i h_{xij} S_i (T_j - T_i) + \Phi_i \\ m_i = \rho_i V_i \end{cases}$$

Where :

$$DFS = \alpha_i G_i \left(W \cdot m^{-2} \right)$$

- DFS : Solar Flux Density absorbed by the material (i)
- α_i : Absorptivity coefficient of the material (i)
- G_i : Solar flux density incident on the surface of the medium (i)
- Φ_i : Source or heat sink in $(W \cdot m^{-2})$
- j : Index of the medium for which (T_j) is a potential connected to potential (T_i)
- h_{xij} : Heat transfer coefficient according to mode x (conduction, convection, or radiation) between mediums i and j in $W/(m^2 \cdot K)$
- S_i : Area of the considered section in m^2

Thermo-physical properties of materials:

Construction	Material	Thermal Conductivity (W/mK)	Specific Heat Capacity (J/kgK)	Density (kg/m^3)
Walls	Brick	1.31	800	1700
Roofs	Terracotta Tiles	1.0	800	1400


Modelica's Thermal Model Implementation

IloomiBuildingTestCase ASCII.mo



- ▶ Beam horizontal radiation
- ▶ Diffuse horizontal radiation
- ▶ Air temperature
- ▶ Wind speed
- ▶ Wind direction
- ▶ Relative humidity
- ▶ Cloud cover

IloomiMultizoneTestCase.mo




Graphical Representation of the 0D Model Captured in Dymola




*Additional details in
the « Numerical
Modeling »
subsection of the
report*

5- SIMULATION RESULTS AND ANALYSIS



5- SIMULATION RESULTS AND ANALYSIS



Simulation parameters


Parameters	Value
Wall Thickness	0.3 m
Roof Thickness	0.01 m
Clothing Insulation	0.5 clo
Metabolic Rate	1.2 met
T_start	20°C
Absortivity	0.5
Epsilon	0.9

Parameters	Value
Surface Temperatures	Off
Internal Heat Sources	On
Internal Moisture Sources	On
Air Paths	Off
Ventilation Rates	On
Ideal Heating & Cooling Loads	Off
Thermal Comfort	On
Hygrothermal Simulation	Off


Summary tables of the parameters used for the simulation

Thermal Comfort Indices: PMV and PPD

Predicted Mean Vote



Predicted Percentage of Dissatisfied



The PMV scale from -3 (cold) to +3 (hot)

Relationship between the predicted mean vote (PMV) and the percentage of dissatisfied (PPD)


Temperature Profiles Analysis: July Results

	Tmax °C	Tmin °C
Exterior Ambiance	35.77	12.39
Zone 1	29.07	16.54
Zone 2	29.52	16.61
Zone 3	36.95	12.80




ASHRAE*
recommendations

Winter	Summer
20°C to 24°C	24°C to 26.5°C

*American Society of Heating,
Refrigerating and Air-Conditioning
Engineers



Temperature Over Time for Month: juillet





Zones Comparison : March

	Max Temperat ure °C	HR %	PPD	PMV
Exterior Ambiance	19.31	0.6	-	-
Zone 1	13.75	0.6	1	-3
Zone 2	14.18	0.6	1	-3
Zone 3	19.70	0.6	0.5	-1.55

ASHRAE*
recommendations


Winter	Summer
20°C to 24°C	24°C to 26.5°C

*American Society of Heating,
Refrigerating and Air-Conditioning
Engineers



Building Thermal Behavior Analysis

Simulation carried out with CAP RENOV (Method 3CL-2021)



6- CONCLUSION AND PERSPECTIVES

Conclusion & Perspectives

- ✓ Successfully established an automatic thermal model to study building behavior.
- ✓ Simulations can now be initiated using the questionnaire and the building address.
- ✓ Gained experience using new tools and discovered the Buildingsystems library.
- Need to refine and label the home's energy consumption for optimal thermal comfort. Considering heating and cooling systems in the model and proposing insulation solutions.
- Incorporate solar masks in the model.



7- MY EXPERIENCE

References

- Connaissance des Énergies. (n.d.). Mix énergétique de la France. Connaissance des Énergies. <https://www.connaissancedesenergies.org/fiche-pedagogique/mix-energetique-de-la-france>
- "The Role of CFD in Evaluating Occupant Thermal Comfort." SimulationHub Blog. <https://www.simulationhub.com/blog/role-of-cfd-in-evaluating-occupant-thermal-comfort>
- Anderson Energy. (n.d.). How to Quantify Comfort with PMV. Anderson Energy. <https://andersonenergy.com.au/how-to-quantify-comfort-with-pmv/>
- ResearchGate. (n.d.). Predicted percentage dissatisfied (PPD) as a function of predicted mean vote (PMV). ResearchGate. https://www.researchgate.net/figure/Predicted-percentage-dissatisfied-PPD-as-a-function-of-predicted-mean-vote-PMV_fig1_305755583

THANK YOU 😊